

SEWERAGE FLOW SCHEDULE (SUMMARY)																
Complied by: Kathy Gao Checked by: Darren Sheather								Date: 26-Sep-21 Date: 26-Sep-21								
Plan No. 91-25368-1A								Location: Chelsea Gardens Description: Moss Vale Stage 1A, 1B & 1C							26-Sep-21 26-Sep-21	
SUMMARY																
SECTION	CHAINAGE	TOTAL AREA	TOTAL Grav	TOTAL Grav + Pump	PIPE SIZE (DN)	PIPE SIZE (ID)	PIPE GRADE	DESIGN FLOW (DF)	Qf (Capacity)	Actual	SELF CLEANSING	SLIME CONTROL	Capacity			
	m	Ha	EP	EP	mm	mm	%	L/s	L/s	PDWF			Deficit			
A-B	00	36.02	1201	1201	225	225	0.5	28.13	32.20	9.38	Self Cleansing OK	NA	OK			
B-C	00	15.31	557	557	225	225	0.6	16.27	35.29	5.42	Self Cleansing OK	NA	OK			